



TAMIL NADU FIRE AND RESCUE SERVICES

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and
Tamil Nadu Fire Service Rule 1990 - Appendix-III)

Licence No: 11333/FL/NMSB/2026

District Office,

Serial No: 1757/2026

Fire and Rescue Service,

Coimbatore District.

Dated: 23/07/2026

ISSUE OF FIRE LICENSE

Ref: (1) Letter no: 406149 from the PRANA AYURVEDIC CARE
HOSPITAL Dated: 15/07/2026

The Fire License is hereby granted under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for Running of Ayurvedic Care Hospital In the name of **M/s. PRANA AYURVEDIC CARE HOSPITAL, S.F.No: 224/1, VELATHAMMAN KOVIL STREET, MOPPERIPALAYAM VILLAGE AND PANCHAYAT, SULUR TALUK, Coimbatore, 641659**. Consisting of Ground floors with the Height of 3.70 Meters and total built-up area in 301.47 Sq.mt within the jurisdiction of SULUR based on the inspection was done by the - SO ANNUR on 21/07/2026. Subject to the condition noted thereon and such other conditions as may be prescribed. This licence is valid for **THREE YEAR from 23/07/2026 to 22/07/2029 and should be renewed on 23/07/2029**.

CONDITIONS

1. All fire fighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. The staff should be trained in preliminary fire fighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. "Mock drill" should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do's & Don'ts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained as per IS 39646 : 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

Signature Not Verified

Signed by: District Officer W.R
Coimbatore District,
Western Region - District Officer,
Home Department

Dated: 23/07/2026, 1757/2026

District Officer,

Fire and Rescue Services



Coimbatore District

To:

**M/s. PRANA AYURVEDIC CARE HOSPITAL,
S.F.No: 224/1, VELATHAMMAN KOVIL STREET,
MOPPERIPALAYAM VILLAGE AND PANCHAYAT,
SULUR TALUK, Coimbatore, 641659.**

Signature Not Verified

Signed by: District Officer W.R
Coimbatore District,
Western Region - District Officer,
Home Department
Date:23-Jul-2026 15:53:39